



12. What type of communication equipment is supplied with each buildings alarm? (phone line, cell, network, etc...)
  - a. All communication is through phone line only.
13. Will bid opening be public? If so, where is the location of the opening?
  - a. Yes. As stated on page 1, 212 South Lake Drive, Lexington, SC, 29072.
14. What type of control panels are at each location?
  - a. See System Inspection Report.
15. Are the control panels "locked out"?
  - a. The systems are locked out. It would be the responsibility of the successful bidder at their expense to reprogram the systems.
16. Can the control panels be programmed with a new receiver number and account number?
  - a. Yes, but it would be the responsibility and at the cost of the bidder.
17. When referring to "Tornado System Maintenance" can you clarify what type of system this is? Is it a Voice Evacuation System?
  - a. Yes this is a voice activated system and with regards to maintenance it would be the responsibility of the successful bidder to work the County of Lexington to test and make repairs if needed.
18. In the past 12 months, how many service calls were needed at each location?
  - a. There were approximately 40 total calls.
19. When were existing systems installed at each location?
  - a. Systems range in approximate age from one (1) year to 25 years.
20. Can you offer zone descriptions of equipment for each location or tell us how many devices are located at each location?
  - a. See System Inspection Report.
21. When referring to "maintenance" in the bid, can you specify or give an example of what this would involve? Typically, there is very little maintenance necessary once the system is installed so we would like to get clarification on what this means.
  - a. Items such as checking non-working key pads, checking systems if there is a alarm call, working with site staff on non-working equipment to determine if it is an operator error or actual equipment issue.
22. The term "Inspections" usually refers to the required annual inspections for a fire alarm system- can you clarify what you expect or give an example of an inspection that you would want done on a security system, fire system and tornado system on a semi-annual and annual basis?
  - a. Yes it would be the responsibility of the successful bidder to visit each site semi-annually to check operation of equipment and make any adjustments as necessary to ensure equipment remains in operational condition.
23. Is the billing of services to be done per location on a monthly basis? Or for the total number of locations on a semi-annual or annual basis? Please specify the required billing of services.
  - a. Semi annually for all locations.
24. Can we receive copies of the previous fire alarm inspections? If not could we at least get the counts of the devices?
  - a. See System Inspection Report.

- 25. Could we get a list of the manufacturers of the fire alarm systems, security systems, and tornado systems at each building?
  - a. See System Inspection Report.
- 26. Does the county own all of the equipment (Is any of it leased?)
  - a. The County of Lexington owns the equipment.
- 27. Do you have a ball park number of hours last year that was used for maintenance on the systems, not including inspections?
  - a. No we do not.
- 28. Are we to include the cost of parts in our bid price?
  - a. Please see Lot #7 on page 22.

**BID OPEN DATE HAS BEEN CHANGED TO JULY 28, 2014 @ 3:00 PM. E.S.T.**

Offerors must acknowledge receipt of this amendment by one of the following methods: (a) By signing and returning one copy of this amendment with your bid; (b) By acknowledging receipt of this amendment on each copy of the bid submitted; or separate letter which includes a reference to the solicitation and amendment numbers. Failure of your acknowledgment to be received at the Purchasing Office prior to the hour and date of the opening may result in rejection of your offer. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter, provided such letter makes reference to the solicitation and this amendment and is received prior to the opening hour and date specified.




Angela M. Seymour  
Procurement Officer

CONTRACTOR: \_\_\_\_\_

NAME & TITLE OF AUTHORIZED REPRESENTATIVE \_\_\_\_\_

AUTHORIZED SIGNATURE \_\_\_\_\_



Jeffrey A. Hyde, CPPB.  
Procurement Manager

**BUILDING SERVICES  
ALARM SYSTEM EQUIPMENT  
VARIOUS BUILDINGS**

BUILDING NAME	PANEL BRAND/ MODEL F-FIRE S-SECURITY	MOTION DETECTOR	SMOKE DETECTOR	HEAT DETECTOR	KEY PAD	STROBE LIGHT	GLASS BREAK	DOOR CONTACT	FIRE PULL STATION	FIRE HORN & STROBE	SIREN
COURTHOUSE	MAGNUM 1016 S MAGNUM 6000 F TORNADO PANEL (1)	13	20	2	2	0	0	0	4	5	TORNAD O BORN 7
SWANSEA MAGISTRATE	MAGNUM 1000	1	0	0	1	0	0	2	0	1	1
WELLNESS CENTER	MAGNUM 1000	2	0	0	1	4	0	0	1	1	1
PUBLIC WORKS	MAGNUM 1000	5	4	1	2			4	0	0	1
BALLPARK RADIO TOWER BLDG. #1	MAGNUM 854 S/F	1	2	0	1	1	0	1	0	0	1
BALLPARK RADIO TOWER BLDG. #2	(WORKS OFF #1 BLDG.)	1	2	0	1	0	0	1	0	0	1
AUX ADMIN RECORDS	MAGNUM 1000	3			1			0			1
SHERIFFS TRAIN	MAGNUM 1000 SIMPLEX	5			1			0			1
CORONERS OFFICE	MAGNUM 1000 SIMPLEX	2			2			6			1



**BUILDING SERVICES  
ALARM SYSTEM EQUIPMENT  
LIBRARIES**

BUILDING NAME	PANEL BRAND/ MODEL F-FIRE S-SECURITY	MOTION DETECTOR	SMOKE (S) DETECTOR / DUCT (D) DETECTOR	HEAT DETECTOR	KEY PAD	STROBE LIGHT	GLASS BREAK	DOOR CONTACT	FIRE PULL STATION	FIRE HORN (H) & STROBE (S)	SIREN & SIREN DRIVER (SD)
CHAPIN LIBRARY	MA1008 (S)	3	0	0	2	0	8	3	0	0	3
IRMO LIBRARY	SIMPLEX 4004 F MA1016 S	4	19 (S) 2 (D)	0	2	0	8	5	4	4 (H) 8 (S)	1
LEXINGTON LIBRARY	SIMPLEX 4020 F MA3000 S	8	13 (S) 13 (D)	14	2	0	8	16	10	32 (H) 10 (S)	3 1 (SD)
CAYCE-WEST COL. LIBRARY	NAPCO S MAGNUM 1000 F	2	0	0	2	0	0	8	8	7	1
GILBERT LIBRARY	SIMPLEX 4001-9403 F MAGNUM 1000 S	3	2 (S)	0	1	0	0	0	3	1	1
GASTON LIBRARY	SIMPLEX 4001-9403 F MAGNUM 1000	3	2 (S)	0	1	0	0	0	3	1	1
BATESBURG LIBRARY	MAGNUM 1000	2	7	0	2	0	0	3	0	0	1
SWANSEA LIBRARY	MAGNUM 1000 FIRELITE MS-5	5	6	2	2	3	0	3	3	9	1
PELION LIBRARY	MAGNUM 1000 SIMPLEX 4000	2	8	0	2	0	0	3	2	2	1
*Updated 5/2003 SOUTH CONCORD	MAGNUM 1000 FIRELITE MS-5	5	6	2	2	3	0	3	3	9	1

**BUILDING SERVICES  
ALARM SYSTEM EQUIPMENT  
FIRE FACILITIES**

BUILDING NAME	PANEL BRAND/ MODEL F-FIRE S-SECURITY	MOTION DETECTOR	SMOKE DETECTOR	HEAT DETECTOR	KEY PAD	STROBE LIGHT	GLASS BREAK	DOOR CONTACT	FIRE PULL STATION	FIRE HORN & STROBE	SIREN
AMICK'S FERRY FIRE STATION	SIMPLEX 4001 F	0	3	1	0	0	0	0	0	0	1
CROSSROADS FIRE STATION	SIMPLEX 4001 F	0	3	1	0	1	0	0	0	0	1
MACK EDISTO FIRE STATION	SIMPLEX 4000 F	0	5	2	0	0	0	0	0	0	1
RED BANK FIRE STATION	SIMPLEX 4001 F	0	2	2	0	3	0	0	1	0	0
SWANSEA FIRE STATION	SIMPLEX 4001 F	0	2	2	0	4	0	0	1	0	0
TRAINING FACILITY	MAGNUM ALERT 854/108/1010 F-S	4	7	3	1	1	4	7	0	0	1
SOUTH CONGARRE FIRE STATION	SAFEGUARD PLUS N3400	0	8	0	1	1	0	0	0	2	0
SHARPES HILL	FIRE LITE MS-5	0	1	0	0	0	0	0	0	1	0
CEDAR GROVE	FIRE LITE MS-5	0	1	1	0	0	0	0	1	1	0
CORLEY HILL	FIRELITE MS-5	0	1	1	0	0	0	0	1	1	0
LAKE MURRAY	FIRE LITE MS-5 +(3) C.O. DETS	0	5	1	0	0	0	0	1	4	0
CHADIN	FIRE LITE MS-5 +(3) C.O. DETS	0	5	1	0	0	0	0	1	4	0

**BUILDING SERVICES  
ALARM SYSTEM EQUIPMENT  
SHERIFF'S FACILITIES**

BUILDING NAME	PANEL BRAND/ MODEL F-FIRE S-SECURITY	MOTION DETECTOR	SMOKE DETECTOR	HEAT DETECTOR	KEY PAD	STROBE LIGHT	GLASS BREAK	DOOR CONTACT	FIRE FULL STATION	FIRE HORN & STROBE	SIREN
SHERIFF'S OFFICE MAIN JAIL	FireLite MS-10	0	36	3	2	0	0	0	10	16	1
SHERIFF'S OFFICE MAIN JAIL MAINTENANCE	NAPCO 6000 S/F	5	0	0	0	0	0	0	0	0	1
SHERIFF'S OFFICE ANNEX	NAPCO S/F MAGNUM ALERT 1000	0	24	0	0	0	0	0	6	3	0
SHERIFF'S OFFICE KITCHEN	ANSUL R-102 S/F	0	3	0	0	0	0	0	6	2	0
SHERIFF'S OFFICE BUNDRICK ISLAND	NAPCO 1000	1 & 2 PE	0	0	1	0	0	2	0	0	1

**Lexington Judicial Administration Center  
FIRE ALARM AND DETECTION SYSTEM**

**BILL OF MATERIAL**

<b>QTY</b>	<b>MODEL NO</b>	<b>DESCRIPTION</b>	<b>CATALOG #</b>
1	MMB-2	MXL--MAIN BOARD	5000
1	MKB-2	DISPLAY PKG	5000
1	MPS-6	POWER SUPPLY	5000
1	MOM-4	OPT MOD MAIN BOARD	5000
1	ALD-2I	LOOP BOARD	5000
1	MME-KIT	ENCL & MTG PL	5000
1	MHD-1	DEAD FRONT MIDDLE PNL	5000
1	MHD-2	DEAD FRONT LOWER PNL	5000
1	MDL-1	CLEAR LENS	5000
1	MDB-1	SHT METAL BNK PLT	5000
45	TRI-B6M	INTERFACE MOD	6170
2	TRI-S	INTERFACE MOD SINGLE	6179
2	TRLR	INTER MOD W/ RELAY	6179
9	TRLR	INFUT MOD DUAL	6179
3	TRLD	REMOTE COMMAND	5039
2	RCC-1	MANUAL STATION	6182
18	MSI-10B	FIRE PRINT DETECTOR	6175
118	FF-11	DETECTOR BASE	6175
91	DB-11	HEAT DETECTOR	6176
13	FPR-11	DUCT HOUSING	6178
40	AD-11P	SAMPLING TUBE	6178
40	STA-6	SYNC MOD DUAL	5553
1	DSC	AUX PWR SUP	3362
4	PAD-3	STROBE	2539
123	U-MCS	HORN STROBE	2555
41	U-MHST-MCS	WEATHERPROOF STATION	N/A
1	MSM-K-WP		

**Lexington Courthouse  
FIRE ALARM AND DETECTION SYSTEM**

**BILL OF MATERIAL**

QTY	MODEL NO	DESCRIPTION	CATALOG #
1	MMB-2	MXL - MAIN BOARD	5000
1	MKB-2	DISPLAY PKG	5000
1	MPS-6	POWER SUPPLY	5000
2	MOM-4	OPT MOD MAIN BOARD	5000
4	ALD-2H	LOOP BOARD	5000
1	MME-KIT	ENCL & MTG FL	5000
1	MME-3	DOOR ENC PKG	5000
1	MSR-1	RAIL KIT	5000
1	MHD-3	DEAD FRONT PNL	5000
2	MHD-1	DEAD FRONT MIDDLE PNL	5000
2	MHD-2	DEAD FRONT LOWER PNL	5000
1	MDL-1	CLEAR LENS	5000
2	MDG-1	LOUVER PLATE PKG	5000
1	MDB-1	SH METAL BSK FLT	5000
1	BB-55	BATTERY BOX	5000
48	TRL-R6M	INTERFACE MOD	6170
9	TRL-S	INTERFACE MOD SINGLE	6179
73	TRL-R	INTER MOD W/ RELAY	6179
9	TRLD	INPUT MOD DUAL	6179
1	RCC-1	REMOTE COMMAND	5039
1	SL28	DIG COMM	4000
42	MSL-10B	MANUAL STATION	6182
248	FP-11	FIRE PRINT DETECTOR	6175
269	DB-11	DETECTOR BASE	6175
64	FPR-11	HEAT DETECTOR	6176
43	AB-11P	DUCT HOUSING	6178
43	STA-6	SAMPLING TUBE	6178
1	D9C	SYNC MOD DUAL	5353
1	PAD-3-MB	AUX PWR SUP	3362
1	PAD-3	AUX PWR SUP	3362
176	U-MCS	STROBE	2539
68	U-MEST-MCS	HORN STROBE	2555

